

Light efficiency:

91 Lumen/Watt

Light quality:

CRI: 92,8

Color temperature:

2669 K

Output: 1006 lm

Peak: 467 cd

Power: 11,0 W

PF: 1,0



Product name:

Pegasus-4-0508-927-L6F

Item number:

FLNP/L/09D0508/927/L6F

Date and time:

08.04.2021 14:05:38

Description:

Rank: F9-8GA

Toleranzen:

Lumen +/-4%

Candela +/-2,5%

Colour Temp +/-35 K

CRI +/-0,7

Angular Resolution 1 Grad step


Last Calibration 20-05-2020

Pruefer: Peter Ulrich

Pruefort: Lichtlabor

Gaustrasse 13

55411 Bingen am Rhein




CIE 1931


x: 0,463



y: 0,412

Spectra




Power






TM30: 92,2



CRI: 92,8 (R1-R8)



CRI R values, only R1-R8 are used to calculate final CRI value

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
92,9	95,9	97,6	93,6	92,6	95,6	92,3	82,0	59,9	89,7	94,8	83,5	93,7	97,8	88,4


TM30 C values, 16 binned values out of total of 99 C values

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
91,1	92,3	89,9	93,9	95,3	95,0	94,6	97,6	95,6	92,2	90,0	90,1	91,9	88,4	92,2	86,6

CQS Q values

Q1	Q2	Q3	Q4	Q5	Q6	Q7	Q8	Q9	Q10	Q11	Q12	Q13	Q14	Q15
87,7	95,0	89,0	89,3	91,5	90,9	90,3	91,9	96,7	93,4	93,1	92,6	92,1	86,3	86,7

CQS: 90,5



Color parameters

Color temperature	Color rendering index	Red component	Color fidelity	Color gamut	Color quality scale	Color coordinate cie 1931	Color coordinate cie 1931	Color coordinate	Color coordinate	Color deviation from black body
CCT	CRI	CRI R9	TM30 Rf	TM30 Rg	CQS	x	y	u	v	Δuv
2669 K	92,8	59,9	92,2	99,8	90,5	0,463	0,412	0,264	0,352	0,0004







Rf 92,2


Fidelity index Rf

Rg 99,8

Gamut index Rg

Hue Bin	R _f	Graphic shifts (%)	
		Chroma	Hue
1	91	-5%	0%
2	92	-3%	3%
3	90	-1%	5%
4	94	0%	3%
5	95	1%	3%
6	95	3%	1%
7	95	0%	-3%
8	98	0%	-1%
9	96	-2%	1%
10	92	-2%	5%
11	90	1%	7%
12	90	5%	1%
13	92	3%	-5%
14	88	4%	-8%
15	92	-1%	-5%
16	87	-3%	-10%





Beam intensities from 1-20m

1m	2m	3m	4m	5m	6m	7m	8m	9m	10m	11m	12m	13m	14m	15m	16m	17m	18m	19m	20m
3,3ft	6,6ft	9,8ft	13,1ft	16,4ft	19,7ft	23ft	26,2ft	29,5ft	32,8ft	36,1ft	39,4ft	42,7ft	45,9ft	49,2ft	52,5ft	55,8ft	59,1ft	62,3ft	65,6ft
448lx	112lx	50lx	28lx	18lx	12lx	9lx	7lx	6lx	4lx	4lx	3lx	3lx	2lx	2lx	2lx	2lx	1lx	1lx	1lx
41,6fcd	10,4fcd	4,6fcd	2,6fcd	1,7fcd	1,2fcd	0,8fcd	0,7fcd	0,5fcd	0,4fcd	0,3fcd	0,3fcd	0,2fcd	0,2fcd	0,2fcd	0,2fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd

Intensities in 0° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
448	450	456	462	467	453	382	263	150	86	57	43	43	55	52	39	27	16	5	0
100%	101%	102%	103%	104%	101%	85%	59%	34%	19%	13%	10%	10%	12%	11%	9%	6%	4%	1%	0%

Intensities in 90° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
448	446	443	439	432	423	412	399	382	362	335	295	239	176	119	73	38	14	1	1
100%	100%	99%	98%	96%	94%	92%	89%	85%	81%	75%	66%	53%	39%	27%	16%	8%	3%	0%	0%

Intensities in 180° c-plane


0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
448	450	456	462	467	453	382	263	150	86	57	43	43	55	52	39	27	16	5	0
100%	101%	102%	103%	104%	101%	85%	59%	34%	19%	13%	10%	10%	12%	11%	9%	6%	4%	1%	0%

Intensities in 270° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
448	446	443	439	432	423	412	399	382	362	335	295	239	176	119	73	38	14	1	1
100%	100%	99%	98%	96%	94%	92%	89%	85%	81%	75%	66%	53%	39%	27%	16%	8%	3%	0%	0%

Beam angle 50%	Field angle 10%	Cutoff angle 2,5%	Intensity ratio in 120° cone	Intensity ratio in 90° cone
89,8°	139,2°	175,9°	85,4%	68,3%

ISO candela diagram




10%	45 cd
20%	90 cd
30%	134 cd
40%	179 cd
50%	224 cd
60%	269 cd
70%	314 cd
80%	358 cd
90%	403 cd

Conditions:

Number of c-planes: 16

Candela at center: 448 cd

ISO lux diagram



3%	0,134 lx
5%	0,224 lx
10%	0,448 lx
30%	1,34 lx
50%	2,24 lx

Conditions:

Number of c-planes: 16

Lux at center: 4,48 lx

Lux distribution on a surface when lamp is mounted at 10 meters from the surface.

Glare Evaluation According to UGR


p Ceiling		70	70	50	50	30	70	70	50	50	30
p Walls		50	30	50	30	30	50	30	50	30	30
p Floor		20	20	20	20	20	20	20	20	20	20
Room size X Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	16,8	17,9	17,0	18,2	18,4	24,5	25,5	24,7	25,8	26,0
	3H	18,2	19,3	18,6	19,6	19,8	25,5	26,6	25,9	26,9	27,1
	4H	18,9	19,9	19,3	20,2	20,4	25,9	27,0	26,3	27,3	27,5
	6H	19,4	20,3	19,7	20,6	21,0	26,3	27,2	26,6	27,5	27,9
	8H	19,6	20,5	19,9	20,8	21,2	26,4	27,3	26,7	27,6	28,0
	12H	19,7	20,5	20,0	20,9	21,3	26,4	27,3	26,8	27,6	28,0
4H	2H	17,3	18,4	17,7	18,6	18,9	24,2	25,2	24,6	25,5	25,8
	3H	19,1	19,9	19,4	20,3	20,7	25,5	26,3	25,8	26,7	27,1
	4H	19,8	20,6	20,2	21,0	21,6	25,9	26,7	26,3	27,1	27,6
	6H	20,4	21,2	20,9	21,5	21,9	26,3	27,0	26,8	27,4	27,7
	8H	20,6	21,3	21,1	21,7	22,1	26,4	27,1	26,9	27,5	27,8
	12H	20,8	21,4	21,3	21,8	22,3	26,5	27,0	26,9	27,5	27,9
8H	4H	20,1	20,9	20,6	21,2	21,6	25,8	26,5	26,3	26,9	27,3
	6H	20,9	21,5	21,4	21,9	22,5	26,3	26,8	26,8	27,3	27,8
	8H	21,3	21,7	21,8	22,3	22,9	26,5	26,9	27,0	27,5	28,1
	12H	21,5	21,9	22,1	22,4	23,0	26,6	27,0	27,2	27,5	28,1
12H	4H	20,2	20,8	20,7	21,2	21,6	25,8	26,4	26,3	26,8	27,3
	6H	21,1	21,5	21,6	22,0	22,7	26,3	26,8	26,8	27,3	27,9
	8H	21,4	21,8	22,0	22,3	22,9	26,5	26,9	27,1	27,4	28,0
Variation of the observer position for the luminaire distance S											
S = 1.0H		0,7 / -0,5					0,5 / -0,7				
S = 1.5H		1,5 / -0,8					1,4 / -1,9				
S = 2.0H		2,3 / -0,8					2,6 / -3,1				
Standard table		n/a					n/a				
Correction summand		n/a					n/a				
Corrected glare indices referring to 1006 lm total luminous flux											

Coefficients of Utilization

Ceiling reflectance	80				70				50			30			10			0
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR	(RCR: Room Cavity Ratio) Room Values are expressed as percentage of Lumens delivered to the task surface																	
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98
1	110	105	102	98	107	103	100	97	99	96	93	94	92	90	91	89	87	85
2	101	94	88	83	99	92	87	82	88	84	80	85	81	78	82	79	76	74
3	94	84	77	71	91	83	76	71	79	74	69	77	72	68	74	70	66	64
4	87	76	68	62	84	75	67	62	72	66	61	69	64	60	67	63	59	57
5	80	69	61	55	78	68	60	54	65	59	54	63	58	53	61	56	52	50
6	75	63	55	49	73	62	54	49	60	53	48	58	52	48	56	51	47	45
7	70	57	49	44	68	57	49	44	55	48	43	53	47	43	52	47	42	41
8	65	53	45	40	64	52	45	39	51	44	39	49	43	39	48	43	39	37
9	61	49	41	36	60	48	41	36	47	40	36	46	40	35	45	39	35	33
10	58	45	38	33	56	45	38	33	44	37	33	43	37	32	42	36	32	31

LAMPS (number of lamps)


Luminaire budgetary diagram



Zonal Lumen Summary

0°-10°	10°-20°	20°-30°	30°-40°	40°-50°	50°-60°	60°-70°	70°-80°	80°-90°
42,8 lm	128 lm	205 lm	223 lm	161 lm	100 lm	66,7 lm	43,4 lm	18,6 lm
90°-100°	100°-110°	110°-120°	120°-130°	130°-140°	140°-150°	150°-160°	160°-170°	170°-180°
4,41 lm	3,40 lm	2,69 lm	2,33 lm	1,95 lm	1,53 lm	1,13 lm	0,690 lm	0,232 lm

Warmup curve



Warmup result

Warmup time:	15 min 40 sec
Warmup variation	-2,8%

Warmup conditions

Stable period:	15 min
Stable change max:	2,0%
Minimum time:	15 min

Color temperature change

CCT start	CCT change	CCT end
2671 K	-2 K	2669 K

Output change

Output start	Output change	Output end
1031 lm	-25 lm	1006 lm