



Light efficiency:

60 Lumen/Watt

Light quality:

CRI: 93,6

Color temperature:


6450 K

Output: 572 lm

Peak: 161 cd

Power: 9,6 W

PF: 1,0



Product name:

**Pegasus-5\_0510\_965\_Cover-Square-White**

Item number:

**FL/L2C/09E/0510/965/CSW**

Date and time:

**03.04.2025 10:27:04**

Description:

**Tolerances:**

**Lumen +/-4%**

**Candela +/-2,5%**

**Colour Temp +/-35 Kelvin**

**CRI +/-0,7**

**Angular Resolution: 1 Degree Step**

**Last Calibration 13.10.2023**

**Tester:**


**Peter Ulrich**

**Test Site:**

**Lichtlabor**


**Gaustrasse 13**

**55411 Bingen am Rhein**





CIE 1931  
x: 0,314  
y: 0,329

Spectra




Power


Voltage: 48,0 V  
Current: 0,200 A  
Frequency: 0 Hz



**TM30: 87,6**



**CRI: 93,6 (R1-R8)**



CRI R values, only R1-R8 are used to calculate final CRI value

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
95,3	99,4	97,2	89,2	91,3	92,8	92,5	90,9	85,5	96,1	91,1	61,9	98,3	99,1	92,2


TM30 C values, 16 binned values out of total of 99 C values

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
88,5	94,4	93,5	91,9	83,7	90,5	90,5	83,0	82,1	76,7	83,8	95,3	90,3	90,9	80,0	92,6

CQS Q values

Q1	Q2	Q3	Q4	Q5	Q6	Q7	Q8	Q9	Q10	Q11	Q12	Q13	Q14	Q15
86,9	96,1	86,8	79,9	82,9	85,4	93,1	95,5	98,7	97,3	94,6	94,9	95,5	94,9	92,7

**CQS: 90,0**



## Color parameters

Color temperature	Color rendering index	Red component	Color fidelity	Color gamut	Color quality scale	Color coordinate cie 1931	Color coordinate cie 1931	Color coordinate	Color coordinate	Color deviation from black body
CCT	CRI	CRI R9	TM30 Rf	TM30 Rg	CQS	x	y	u	v	$\Delta uv$
6450 K	93,6	85,5	87,6	95,8	90,0	0,314	0,329	0,199	0,312	0,0009







## Rf 87,6


Fidelity index Rf

## Rg 95,8

Gammut index Rg

Hue Bin	R <sub>f</sub>	Graphic shifts (%)	
		Chroma	Hue
1	89	-3%	2%
2	94	-1%	2%
3	94	-1%	-1%
4	92	-3%	-1%
5	84	-10%	-3%
6	91	-7%	-1%
7	91	-6%	1%
8	83	-6%	8%
9	82	-4%	16%
10	77	0%	15%
11	84	5%	9%
12	95	3%	-1%
13	90	3%	-4%
14	91	-1%	-5%
15	80	8%	-13%
16	93	-4%	1%





## Beam intensities from 1-20m

1m	2m	3m	4m	5m	6m	7m	8m	9m	10m	11m	12m	13m	14m	15m	16m	17m	18m	19m	20m
3,3ft	6,6ft	9,8ft	13,1ft	16,4ft	19,7ft	23ft	26,2ft	29,5ft	32,8ft	36,1ft	39,4ft	42,7ft	45,9ft	49,2ft	52,5ft	55,8ft	59,1ft	62,3ft	65,6ft
161lx	40lx	18lx	10lx	6lx	4lx	3lx	3lx	2lx	2lx	1lx	1lx	1lx	1lx	1lx	1lx	1lx	0lx	0lx	0lx
15fcd	3,7fcd	1,7fcd	0,9fcd	0,6fcd	0,4fcd	0,3fcd	0,2fcd	0,2fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0fcd	0fcd	0fcd

## Intensities in 0° c-plane

0°	9°	18°	27°	36°	45°	54°	63°	72°	81°	90°	99°	108°	117°	126°	135°	144°	153°	162°	171°
161	161	158	151	141	127	110	91	71	51	17	0	0	0	0	0	0	0	0	0
100%	100%	98%	94%	87%	79%	68%	56%	44%	32%	10%	0%	0%	0%	0%	0%	0%	0%	0%	0%

## Intensities in 90° c-plane

0°	9°	18°	27°	36°	45°	54°	63°	72°	81°	90°	99°	108°	117°	126°	135°	144°	153°	162°	171°
161	159	152	141	126	107	87	64	40	17	1	1	1	1	0	0	0	0	0	0
100%	98%	94%	87%	78%	67%	54%	39%	25%	11%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

## Intensities in 180° c-plane


0°	9°	18°	27°	36°	45°	54°	63°	72°	81°	90°	99°	108°	117°	126°	135°	144°	153°	162°	171°
161	161	158	151	141	127	110	91	71	51	17	0	0	0	0	0	0	0	0	0
100%	100%	98%	94%	87%	79%	68%	56%	44%	32%	10%	0%	0%	0%	0%	0%	0%	0%	0%	0%

## Intensities in 270° c-plane

0°	9°	18°	27°	36°	45°	54°	63°	72°	81°	90°	99°	108°	117°	126°	135°	144°	153°	162°	171°
161	159	152	141	126	107	87	64	40	17	1	1	1	1	0	0	0	0	0	0
100%	98%	94%	87%	78%	67%	54%	39%	25%	11%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

Beam angle 50%	Field angle 10%	Cutoff angle 2,5%	Intensity ratio in 120° cone	Intensity ratio in 90° cone
125,7°	198,2°	213,2°	68,8%	45,3%

### ISO candela diagram




10%	16 cd
20%	32 cd
30%	48 cd
40%	64 cd
50%	81 cd
60%	97 cd
70%	113 cd
80%	129 cd
90%	145 cd

#### Conditions:

Number of c-planes: 16

Candela at center: 161 cd

### ISO lux diagram



Mounting height: 10 meters (33 feet)

3%	48,4m lx
5%	80,6m lx
10%	0,161 lx
30%	0,484 lx
50%	0,806 lx

#### Conditions:

Number of c-planes: 16

Lux at center: 1,61 lx

*Lux distribution on a surface  
when lamp is mounted at 10  
meters from the surface.*

### Glare Evaluation According to UGR


p Ceiling		70	70	50	50	30	70	70	50	50	30
p Walls		50	30	50	30	30	50	30	50	30	30
p Floor		20	20	20	20	20	20	20	20	20	20
Room size X      Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	24,1	25,4	24,4	25,8	26,0	23,7	25,0	23,9	25,3	25,5
	3H	25,9	27,3	26,4	27,6	27,8	25,2	26,6	25,6	26,9	27,1
	4H	26,8	28,2	27,3	28,4	28,7	25,9	27,2	26,3	27,5	27,7
	6H	27,8	28,9	28,1	29,2	29,6	26,4	27,6	26,8	27,9	28,3
	8H	28,1	29,3	28,5	29,6	30,0	26,6	27,7	26,9	28,0	28,5
	12H	28,5	29,6	28,8	29,9	30,4	26,7	27,8	27,1	28,1	28,6
4H	2H	24,7	26,1	25,2	26,3	26,6	24,4	25,7	24,8	26,0	26,3
	3H	26,9	28,0	27,3	28,3	28,8	26,3	27,4	26,6	27,7	28,2
	4H	27,9	28,9	28,3	29,3	29,9	27,0	28,0	27,4	28,4	29,0
	6H	28,9	29,9	29,4	30,2	30,6	27,6	28,6	28,1	29,0	29,4
	8H	29,4	30,3	29,9	30,6	31,0	27,9	28,8	28,4	29,1	29,5
	12H	29,8	30,6	30,3	31,0	31,5	28,0	28,8	28,5	29,2	29,7
8H	4H	28,2	29,1	28,7	29,5	29,9	27,5	28,4	28,0	28,7	29,1
	6H	29,5	30,2	30,0	30,6	31,2	28,3	29,0	28,8	29,5	30,1
	8H	30,1	30,7	30,6	31,3	31,9	28,7	29,3	29,2	29,8	30,5
	12H	30,7	31,3	31,3	31,8	32,4	29,0	29,5	29,6	30,0	30,6
12H	4H	28,3	29,0	28,8	29,5	29,9	27,5	28,3	28,0	28,7	29,2
	6H	29,6	30,2	30,1	30,7	31,4	28,5	29,1	29,0	29,7	30,3
	8H	30,3	30,8	30,8	31,3	31,9	28,9	29,5	29,5	30,0	30,6
Variation of the observer position for the luminaire distance S											
S = 1.0H		0,1 / -0,1					0,1 / -0,1				
S = 1.5H		0,1 / -0,1					0,1 / -0,2				
S = 2.0H		0,2 / -0,2					0,3 / -0,4				
Standard table		n/a					n/a				
Correction summand		n/a					n/a				
Corrected glare indices referring to 572 lm total luminous flux											

## Coefficients of Utilization

Ceiling reflectance	80				70				50			30			10			0
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR	(RCR: Room Cavity Ratio) Room Values are expressed as percentage of Lumens delivered to the task surface																	
0	118	118	118	118	115	115	115	115	109	109	109	104	104	104	99	99	99	96
1	106	100	95	91	103	98	93	89	93	89	85	88	85	82	84	81	79	77
2	96	86	79	72	92	84	77	71	80	74	69	76	71	67	72	68	65	62
3	87	75	66	59	84	73	65	58	70	63	57	66	60	55	63	58	54	51
4	79	66	57	49	76	64	56	49	61	54	48	59	52	47	56	50	46	43
5	72	59	49	42	70	57	48	42	55	47	41	52	46	40	50	44	39	37
6	67	53	43	37	64	52	43	36	49	41	36	47	40	35	45	39	34	32
7	62	48	38	32	60	47	38	32	45	37	31	43	36	31	41	35	30	28
8	57	43	35	28	56	42	34	28	41	33	28	39	32	27	38	32	27	25
9	54	40	31	25	52	39	31	25	38	30	25	36	29	25	35	29	24	22
10	50	37	28	23	49	36	28	23	35	28	23	33	27	22	32	26	22	20

LAMPS (number of lamps)


Luminaire budgetary diagram



## Zonal Lumen Summary

0°-10°	10°-20°	20°-30°	30°-40°	40°-50°	50°-60°	60°-70°	70°-80°	80°-90°
15,3 lm	44,5 lm	68,7 lm	85,1 lm	91,8 lm	87,9 lm	74,3 lm	53,8 lm	30,4 lm
90°-100°	100°-110°	110°-120°	120°-130°	130°-140°	140°-150°	150°-160°	160°-170°	170°-180°
8,48 lm	2,73 lm	2,16 lm	1,95 lm	1,64 lm	1,30 lm	0,960 lm	0,588 lm	0,198 lm

## Warmup curve



## Warmup result

Warmup time:	Lamp stabilized in 18 min 43 sec
Warmup variation	-3,9%

## Warmup conditions

Stable period:	15 min
Stable change max:	2,0%
Minimum time:	15 min

## Color temperature change

CCT start	CCT change	CCT end
6404 K	+46 K	6450 K

## Output change

Output start	Output change	Output end
593 lm	-21 lm	572 lm